


DEVELOPMENT SUMMARY

TOTAL AREA = 2.48 ACRES
 EXISTING ZONING = R-20
 ZONING = RA-5
 SETBACKS:



FRONT = 25'
 SIDE = 5'/15' BETWEEN DWELLINGS
 REAR = 40'

MIN. LOT AREA: 7,000 SF
 MIN. LOT WIDTH: 70 FT (AT BUILDING LINE)
 MIN. UNIT SIZE: 960 SF

PROPOSED LOTS = 7
 PROPOSED DENSITY = 2.82 UPA



Z-111
(2016)



CURVE #	LENGTH	RADIUS	CHORD BEARING	CHORD LENGTH
C185	16.00'	20.00'	100°00'00"	71.72'
C186	14.00'	20.00'	100°00'00"	64.00'
C187	14.00'	20.00'	100°00'00"	64.00'
C188	14.00'	20.00'	100°00'00"	64.00'

LINE #	LENGTH	DIRECTION
L407	86.15'	100°00'00"
L408	54.00'	100°00'00"
L409	20.00'	100°00'00"
L410	86.15'	100°00'00"
L411	126.70'	100°00'00"
L412	86.15'	100°00'00"
L413	20.00'	100°00'00"
L414	86.15'	100°00'00"
L415	20.00'	100°00'00"
L416	20.00'	100°00'00"
L417	20.00'	100°00'00"
L418	20.00'	100°00'00"
L419	20.00'	100°00'00"
L420	20.00'	100°00'00"
L421	20.00'	100°00'00"
L422	20.00'	100°00'00"
L423	20.00'	100°00'00"
L424	20.00'	100°00'00"
L425	20.00'	100°00'00"
L426	20.00'	100°00'00"
L427	20.00'	100°00'00"
L428	20.00'	100°00'00"
L429	20.00'	100°00'00"
L430	20.00'	100°00'00"
L431	20.00'	100°00'00"
L432	20.00'	100°00'00"
L433	20.00'	100°00'00"
L434	20.00'	100°00'00"
L435	20.00'	100°00'00"
L436	20.00'	100°00'00"
L437	20.00'	100°00'00"
L438	20.00'	100°00'00"
L439	20.00'	100°00'00"
L440	20.00'	100°00'00"
L441	20.00'	100°00'00"
L442	20.00'	100°00'00"
L443	20.00'	100°00'00"
L444	20.00'	100°00'00"
L445	20.00'	100°00'00"
L446	20.00'	100°00'00"
L447	20.00'	100°00'00"
L448	20.00'	100°00'00"
L449	20.00'	100°00'00"
L450	20.00'	100°00'00"
L451	20.00'	100°00'00"
L452	20.00'	100°00'00"
L453	20.00'	100°00'00"
L454	20.00'	100°00'00"
L455	20.00'	100°00'00"
L456	20.00'	100°00'00"
L457	20.00'	100°00'00"
L458	20.00'	100°00'00"
L459	20.00'	100°00'00"
L460	20.00'	100°00'00"
L461	20.00'	100°00'00"
L462	20.00'	100°00'00"
L463	20.00'	100°00'00"
L464	20.00'	100°00'00"
L465	20.00'	100°00'00"
L466	20.00'	100°00'00"
L467	20.00'	100°00'00"
L468	20.00'	100°00'00"
L469	20.00'	100°00'00"
L470	20.00'	100°00'00"
L471	20.00'	100°00'00"
L472	20.00'	100°00'00"
L473	20.00'	100°00'00"
L474	20.00'	100°00'00"
L475	20.00'	100°00'00"
L476	20.00'	100°00'00"
L477	20.00'	100°00'00"
L478	20.00'	100°00'00"
L479	20.00'	100°00'00"
L480	20.00'	100°00'00"
L481	20.00'	100°00'00"
L482	20.00'	100°00'00"
L483	20.00'	100°00'00"
L484	20.00'	100°00'00"
L485	20.00'	100°00'00"
L486	20.00'	100°00'00"
L487	20.00'	100°00'00"
L488	20.00'	100°00'00"
L489	20.00'	100°00'00"
L490	20.00'	100°00'00"
L491	20.00'	100°00'00"
L492	20.00'	100°00'00"
L493	20.00'	100°00'00"
L494	20.00'	100°00'00"
L495	20.00'	100°00'00"
L496	20.00'	100°00'00"
L497	20.00'	100°00'00"
L498	20.00'	100°00'00"
L499	20.00'	100°00'00"
L500	20.00'	100°00'00"

SHALLOWFORD PLACE

SITE PLAN

COBB COUNTY, GEORGIA

SEPTEMBER 1, 2016

(9-1-16)

APPLICANT: RSDC1, LLC

PHONE#: 770-573-4801 EMAIL: rsdcprop@gmail.com

REPRESENTATIVE: Ralph Davia

PHONE#: 770-355-8070 EMAIL: rdavia@greydenllc.com

TITLEHOLDER: Brian Carter, Mildred Lampley, Mary L. Rolader,

William Rolader

PROPERTY LOCATION: Located on the north side of Shallowford

Road, east of Lassiter Road

ACCESS TO PROPERTY: Shallowford Road

PHYSICAL CHARACTERISTICS TO SITE: Four (4) existing

lots with three (3) single-family homes

CONTIGUOUS ZONING/DEVELOPMENT

NORTH: R-15/ Hedgerow Subdivision

SOUTH: LRO/ Offices

EAST: R-15/ Hedgerow Subdivision

WEST: RA-5/ Shallowford Gree Subdivision

PETITION NO: Z-111

HEARING DATE (PC): ~~12-06-16~~ 05-02-17

HEARING DATE (BOC): ~~12-20-16~~ 06-20-17

PRESENT ZONING: R-20

PROPOSED ZONING: RA-5

PROPOSED USE: Residential subdivision

SIZE OF TRACT: 2.48 acres

DISTRICT: 16

LAND LOT(S): 400

PARCEL(S): 2, 6, 10, 44

TAXES: PAID X DUE _____

COMMISSION DISTRICT: 2

Adjacent Future Land Use:

North: Neighborhood Activity Center (NAC)

East: Neighborhood Activity Center (NAC)

South: Neighborhood Activity Center (NAC)

West: Neighborhood Activity Center (NAC)

OPPOSITION: NO. OPPOSED _____ PETITION NO: _____ SPOKESMAN _____

PLANNING COMMISSION RECOMMENDATION

APPROVED _____ MOTION BY _____

REJECTED _____ SECONDED _____

HELD _____ CARRIED _____


BOARD OF COMMISSIONERS DECISION

APPROVED _____ MOTION BY _____


REJECTED _____ SECONDED _____

HELD _____ CARRIED _____


STIPULATIONS:





Z-111-2016 GIS



This map is provided for display and planning purposes only. It is not meant to be a legal description.



-  City Boundary
-  Zoning Boundary

APPLICANT: RSDC1, LLC

PETITION NO.: Z-111

PRESENT ZONING: R-20

PETITION FOR: RA-5

ZONING COMMENTS:

Staff Member Responsible: Terry Martin, MPA

Land Use Plan Recommendation: Medium Density Residential (MDR)

Proposed Number of Units: 7 **Overall Density:** 2.82 **Units/Acre**

Staff estimate for allowable # of units: 5 **Units*** **Increase of:** 2 **Units/Lots**

*Estimate could be higher or lower based on engineered plans taking into account topography, shape of property, utilities, roadways, natural features such as creeks, wetlands, etc., and other unforeseen circumstances.

The applicant is requesting a rezoning to the RA-5 single-family residential district in order to develop a seven-lot single-family subdivision. That district’s minimum lot size of 7,000 sq. ft. will be met with the lots ranging from 8,217 sq. ft. to 13,065 sq. ft. The proposed homes will be a minimum of 2,500 square feet and be constructed with brick, stone, stacked stone, cedar shake, board and batten, or combinations thereof. The Code-required 10 foot landscape buffer is provided adjacent to more restrictively zoned (R-15) properties, which is shown.

This request is nearly identical to a request that was approved as Z-35 of 2013, but which reverted to the original R-20 zoning due to a reversionary clause. That application’s site plan resembles the plan the Board of Commissioner’s approved in 2013.

Cemetery Preservation: There is no significant impact on the cemetery site listed in the Cobb County Cemetery Preservation Commission's Inventory Listing which is located in this, or adjacent lot.

APPLICANT: RSDC1, LLC

PETITION NO.: Z-111

PRESENT ZONING: R-20

PETITION FOR: RA-5

SCHOOL COMMENTS:

<u>Name of School</u>	<u>Enrollment</u>	<u>Capacity Status</u>	<u>Number of Portable Classrooms</u>
<u>Shallowford Falls</u>	<u>624</u>	<u>786</u>	<u> </u>
Elementary <u>Simpson</u>	<u>952</u>	<u>865</u>	<u> </u>
Middle <u>Lassiter</u>	<u>2176</u>	<u>2137</u>	<u> </u>

High

- School attendance zones are subject to revision at any time.

Additional Comments: Approval of this petition will cause concern for Cobb County School District, as it will result in a nominal impact on the enrollment for schools already over capacity.

FIRE COMMENTS:

GUEST PARKING: When projects contemplate less than 20 foot separation between units, guest parking shall be provided at a ratio of one-half space for each dwelling unit (1 space/ 2 units).

APPLICANT: RSDC1, LLC
PRESENT ZONING: R-20

PETITION NO.: Z-111
PETITION FOR: RA-5

PLANNING COMMENTS:

The applicant is requesting a rezoning from R-20 to RA-5 for the purpose of a residential subdivision. The 2.48 acre site is located on the north side of Shallowford Road, east of Lassiter Road.

HB-489 Intergovernmental Agreement Zoning Amendment Notification:

Is the application site within one half (1/2) mile of a city boundary? Yes No
If yes, has the city of _____ been notified? Yes No / N/A

Comprehensive Plan

The parcel is within a Medium Density Residential (MDR) future land use category, with R-20 zoning designation. The purpose of the Medium Density Residential (MDR) category is to provide for areas that are suitable for moderate density housing, between two and one-half (2.5) and five (5) dwelling units per acre.

Specific Area Policy Guidelines:

There are no specific policy guidelines for this area in the Comprehensive Plan.

Adjacent Future Land Use:

Northeast: Low Density Residential (LDR)
East: Low Density Residential (LDR)
Southwest: Neighborhood Activity Center (NAC)
West: Medium Density Residential (MDR)

Master Plan/Corridor Study

The property is not located within the boundary of a Plan or Corridor Study

Historic Preservation

After consulting various county historic resources surveys, historic maps, archaeology surveys and Civil War trench location maps, staff finds that no known significant historic resources appear to be affected by this application. No further comment. No action by applicant requested at this time.

Design Guidelines

Is the parcel in an area with Design Guidelines? Yes No
If yes, design guidelines area _____
Does the current site plan comply with the design requirements?

Incentive Zones

Is the property within an Opportunity Zone? Yes No
The Opportunity Zone is an incentive that provides \$3,500 tax credit per job in eligible areas if two or more jobs are being created. This incentive is available for new or existing businesses.

Is the property within an Enterprise Zone? Yes No
The _____ Enterprise Zone is an incentive that provides tax abatements and other economic incentives for qualifying businesses locating or expanding within designated areas for new jobs and capital investments.

Is the property eligible for incentives through the Commercial and Industrial Property Rehabilitation Program? Yes No

APPLICANT: RSDC1, LLC

PRESENT ZONING: R-20

PETITION NO.: Z-111

PETITION FOR: RA-5

PLANNING COMMENTS:

CONT.

The Commercial and Industrial Property Rehabilitation Program is an incentive that provides a reduction in ad valorem property taxes for qualifying redevelopment in eligible areas.

For more information on incentives, please call the Community Development Agency, Planning Division at 770.528.2018 or find information online at <http://economic.cobbcountyga.gov>.

Special Districts

Is this property within the Cumberland Special District #1 (hotel/motel fee)?

Yes No

Is this property within the Cumberland Special District #2 (ad valorem tax)?

Yes No

Is this property within the Six Flags Special Service District?

Yes No

Is the property within the Dobbins Airfield Safety Zone?

Yes No

If so, which particular safety zone is this property within?

CZ (Clear Zone) APZ I (Accident Potential Zone I)

APZ II (Accident Potential Zone II)

Bird / Wildlife Air Strike Hazard (BASH) area

APPLICANT RSCC1, LLC

PETITION NO. Z-111

PRESENT ZONING R-20

PETITION FOR RA-5

WATER COMMENTS: NOTE: Comments reflect only what facilities were in existence at the time of this review.

Available at Development: Yes No

Fire Flow Test Required: Yes No

Size / Location of Existing Water Main(s): 8" DI / N side of Shallowford Rd

Additional Comments:

Developer may be required to install/upgrade water mains, based on fire flow test results or Fire Department Code. This will be resolved in the Plan Review Process.

SEWER COMMENTS: NOTE: Comments reflect only what facilities were in existence at the time of this review.

In Drainage Basin: Yes No

At Development: Yes No

Approximate Distance to Nearest Sewer: 200' W in Shallowford Rd

Estimated Waste Generation (in G.P.D.): A D F= 1,440 Peak= 3,600

Treatment Plant: Big Creek

Plant Capacity: Available Not Available

Line Capacity: Available Not Available

Projected Plant Availability: 0 - 5 years 5 - 10 years over 10 years

Dry Sewers Required: Yes No

Off-site Easements Required: Yes* No *If off-site easements are required, Developer must submit easements to CCWS for review/approval as to form and stipulations prior to the execution of easements by the property owners. All easement acquisitions are the responsibility of the Developer

Flow Test Required: Yes No

Letter of Allocation issued: Yes No

Septic Tank Recommended by this Department: Yes No

Subject to Health Department Approval: Yes No

Additional Comments:

Developer will be responsible for connecting to the existing County water and sewer systems, installing and/or upgrading all outfalls and water mains, obtaining on and/or offsite easements, dedication of on and/or offsite water and sewer to Cobb County, as may be required. Rezoning does not guarantee water/sewer availability/capacity unless so stated in writing by the Cobb County Water System. Permit issuances subject to continued treatment plant compliance with EPD discharge requirements.

APPLICANT: RSDC1, LLC

PETITION NO.: Z-111

PRESENT ZONING: R-20

PETITION FOR: RA-5

STORMWATER MANAGEMENT COMMENTS

FLOOD HAZARD: YES NO POSSIBLY, NOT VERIFIED

DRAINAGE BASIN: Harmony Grove Creek FLOOD HAZARD INFO: Zone X

- FEMA Designated 100 year Floodplain Flood.
- Flood Damage Prevention Ordinance DESIGNATED FLOOD HAZARD.
- Project subject to the Cobb County Flood Damage Prevention Ordinance Requirements.
- Dam Breach zone from (upstream) (onsite) lake - need to keep residential buildings out of hazard.

WETLANDS: YES NO POSSIBLY, NOT VERIFIED

Location: _____

- The Owner/Developer is responsible for obtaining any required wetland permits from the U.S. Army Corps of Engineer.

STREAMBANK BUFFER ZONE: YES NO POSSIBLY, NOT VERIFIED

- Metropolitan River Protection Area (within 2000' of Chattahoochee River) ARC (review 35' undisturbed buffer each side of waterway).
- Chattahoochee River Corridor Tributary Area - County review (_____ undisturbed buffer each side).
- Georgia Erosion-Sediment Control Law and County Ordinance - County Review/State Review.
- Georgia DNR Variance may be required to work in 25 foot streambank buffers.
- County Buffer Ordinance: 50', 75', 100' or 200' each side of creek channel.

DOWNSTREAM CONDITION

- Potential or Known drainage problems exist for developments downstream from this site.
- Stormwater discharges must be controlled not to exceed the capacity available in the downstream storm drainage system.
- Minimize runoff into public roads.
- Minimize the effect of concentrated stormwater discharges onto adjacent properties.
- Developer must secure any R.O.W required to receive concentrated discharges where none exist naturally
- Existing Lake Downstream- Maddux Lake.
Additional BMP's for erosion sediment controls will be required.
- Lake Study needed to document sediment levels.
- Stormwater discharges through an established residential neighborhood downstream.
- Project engineer must evaluate the impact of increased volume of runoff generated by the proposed project on receiving storm system.

APPLICANT: RSDC1, LLC

PETITION NO.: Z-111

PRESENT ZONING: R-20

PETITION FOR: RA-5

STORMWATER MANAGEMENT COMMENTS – Continued

SPECIAL SITE CONDITIONS

- Provide comprehensive hydrology/stormwater controls to include development of out parcels.
- Submit all proposed site improvements to Plan Review.
- Any **spring activity** uncovered must be addressed by a qualified geotechnical engineer (PE).
- Structural fill _____ must be placed under the direction of a qualified registered Georgia geotechnical engineer (PE).
- Existing facility.
- Project must comply with the Water Quality requirements of the CWA-NPDES-NPS Permit and County Water Quality Ordinance.
- Water Quality/Quantity contributions of the existing lake/pond on site must be continued as baseline conditions into proposed project.
- Calculate and provide % impervious of project site.
- Revisit design; reduce pavement area to reduce runoff and pollution.

INSUFFICIENT INFORMATION

- No Stormwater controls shown _____
- Copy of survey is not current – Additional comments may be forthcoming when current site conditions are exposed.
- No site improvements showing on exhibit.

ADDITIONAL COMMENTS

1. This site is located just north of Shallowford Road and is bounded on the north and east by Hedgerow Subdivision and on the west by Shallowford Green Subdivision. Slopes on the site are relatively mild ranging from 2 to 10%. The majority of the site (2/3) drains to the Shallowford Road R/W. The remaining third drains to the east into the Hedgerow Subdivision Recreation Area.
2. Any bypass runoff from the rear of lots 1 through 7 must be directed to the Shallowford Road right-of-way and not to the Hedgerow Rec Area.

APPLICANT: RSDC1, LLC

PETITION NO.: Z-111

PRESENT ZONING: R-20

PETITION FOR: RA-5

TRANSPORTATION COMMENTS:

ROADWAY	AVERAGE DAILY TRIPS	ROADWAY CLASSIFICATION	SPEED LIMIT	JURISDICTIONAL CONTROL	MIN. R.O.W. REQUIREMENTS
Shallowford Road	27,300	Arterial	45 mph	Cobb County	100'

Based on 2011 traffic counting data taken by Cobb County DOT for Shallowford Road.

COMMENTS AND OBSERVATIONS

Shallowford Road is classified as an arterial and according to the available information the existing right-of-way does not meet the minimum requirements for this classification.

RECOMMENDATIONS

Recommend applicant consider entering into a development agreement pursuant to O.C.G.A. 36-71-13 for dedication of the following system improvements to mitigate traffic concerns: a) donation of right-of-way on the north side of Shallowford Road, a minimum of 50' from the roadway centerline.

Recommend applicant be required to meet all Cobb County Development Standards and Ordinances related to project improvements.

Recommend curb and gutter along both sides and sidewalk along one side of proposed development roadway.

Recommend guest parking be located outside of the right-of-way.

STAFF RECOMMENDATIONS

Z-111 RSDC1, LLC

- A. It is Staff's opinion that the applicant's rezoning proposal will permit a use that is suitable in view of the use and development of adjacent and nearby properties. Immediately adjacent to the west exists an RA-5 district subdivision while to the north and east bounding the applicant's proposed 10 ft. landscape buffer lies an R-15 district subdivision.
- B. It is Staff's opinion that the applicant's rezoning proposal will not have an adverse effect on the usability of adjacent or nearby property. The applicant is proposing access directly from Shallowford Road by means of a public street. Also, the applicant is proposing a landscape buffer adjacent to the bounding R-15 zoned properties.
- C. It is Staff's opinion that the applicant's rezoning proposal will not result in a use which would cause an excessive or burdensome use of existing streets, transportation facilities, utilities, or schools. This opinion can be supported by the departmental comments contained in this analysis.
- D. It is Staff's opinion that the applicant's rezoning proposal is in conformity with the policy and intent of the *Cobb County Comprehensive Plan*. The property lies within an area delineated as MDR medium density residential on the future land use map. The *Plan* states that the purpose of the Medium Density Residential (MDR) category is to provide for areas that are suitable for moderate density housing, between two and one-half (2.5) and five (5) dwelling units per acre. The applicant's proposal represents a density of 2.82 units per acre. The abutting subdivision to the west (Shallowford Green) is also zoned RA-5 and also has a density of 3.62 units per acre. Another subdivision in this area is Hedgerow (Unit IIA) at approximately 2.0 units per acre. Also on the north side of Shallowford Road and west of the subject property is Shallowford Trace, zoned RA-5 at a density of 3.45 units per acre.
- E. It is Staff's opinion that there are existing and changing conditions affecting the use and development of the property which give supporting grounds for approving the applicant's rezoning proposal. The property lies adjacent to existing RA-5 zoned property and provides a landscape buffer where it is bounded by the Hedgerow Subdivision which is zoned R-15. The project proposes access directly from Shallowford Road by means of a public street. Also, representing a density of 2.82 units per acre, the proposed development falls well within the projected range of its MDR future land use category of 2.5 to 5 dwelling units per acre.

Based on the above analysis, Staff recommends **APPROVAL** subject to the following conditions:

1. Site plan dated September 1, 2016 with District Commissioner approving minor modifications;
2. Fire Department comments and recommendations;
3. Water and Sewer Division comments and recommendations;
4. Stormwater Management Division comments and recommendations;
5. Department of Transportation comments and recommendations;
6. Owner/developer to enter into a Development Agreement pursuant to O.C.G.A. §36-71-13 for dedication of system improvements to mitigate traffic concerns; and
7. House architecture to be approved by the District Commissioner.

The recommendations made by the Planning and Zoning Staff are only the opinions of the Planning and Zoning Staff and are by no means the final decision. The Cobb County Board of Commissioners makes the final decisions on all Rezoning and Land Use Permits at an advertised public hearing.

Application No. Z-111

Dec. 2016

Summary of Intent for Rezoning

.....


Part 1. Residential Rezoning Information (attach additional information if needed)

- a) Proposed unit square-footage(s): MIN. 2500SF
 - b) Proposed building architecture: BRICK, STONE, STACKED STONE, CEDAR SHAKE, BOARD AND BATTEN
 - c) Proposed selling prices(s): STARTING IN THE HIGH \$500,000's
 - d) List all requested variances: N/A
-
-
-

.....

Part 2. Non-residential Rezoning Information (attach additional information if needed)

- a) Proposed use(s): N/A
 - b) Proposed building architecture: _____
 - c) Proposed hours/days of operation: _____
 - d) List all requested variances: _____
-
-
-



.....

Part 3. Other Pertinent Information (List or attach additional information if needed)

.....

Part 4. Is any of the property included on the proposed site plan owned by the Local, State, or Federal Government?

(Please list all Right-of-Ways, Government owned lots, County owned parcels and/or remnants, etc., and attach a plat clearly showing where these properties are located).

N/A

Applicant Stipulations

Applicant RSDCI, LLC- Zoning Petition No Z-111

- 1 The applicant seeks rezoning from subject property from the existing zoning category R20 to the proposed zoning category of RA5, with reference to the rezoning plan dated May 2, 2017 and filed with the stipulation letter. A copy of the rezoning plan is attached hereto for ease of reference as Exhibit A and incorporated herein by reference.
- 2 The subject property consists of 2.4 acres of total area and shall be developed for a residential community comprised of 7 single family detached residences all a minimum of 7500 square feet
- 3 The proposed residence shall have a minimum of 2500 square feet of heated and cooled living space. The density will not exceed 3 units per acre. There will be no driveway curb cuts on Shallowford Road.
- 4 The proposed residences shall be traditional in style and architecture and will have a minimum 2 car garage. The garage will be used for vehicle parking only
- 5 Residences within the proposed community shall have at minimum 3 sided exteriors comprised of brick, stone, stacked stone, cedar shake, boards and batten finishes with complementary accents, or combination thereof. A four-foot water table made of brick or stone will be installed on rear elevations. The homes to be built are in substantial conformity to the images provided and anything different will be preapproved by the district commissioner.
- 6 Front setbacks will be 25 feet, rear setbacks will be 40 feet, side setbacks will be 20 feet
- 7 The street will be public and will be installed to DOT standards
- 8 The entrance signage will be monument style and will comply with Cobb County standards
- 9 Construction hours will be Monday thru Friday 7:30am- 6pm Saturday 9:00am-5:00 pm Sunday construction will be limited to interior only, if exterior is needed it will be preauthorized by district commissioner
- 10 During development and construction, all reasonable effort will be utilized to preserve trees within the specified buffer. Applicant agrees to establish a minimum 10-foot landscape buffer behind each home, planted with evergreen trees as approved by Cobb County arborist, with the exception of lot 3 which will have a 15 ' planted buffer permanent evergreen landscape buffer along the perimeter of the property adjacent to existing subdivision, except for lot 3 for which there will be a minimum of a 15-foot permanent evergreen landscape buffer. To the extent that any trees are damaged, Applicant shall replant consistent with Cobb County Arborist.
- 11 Minor modifications to the reference Rezoning Plan must be approved by the District Commissioner, as needed or necessary. For purposes of this paragraph, any modifications that increase density, reduce the size of an approved buffer to adjacent property, the relocation of a structure closer to a property line, or increase the height of the building adjacent to the property, which are in direct contradiction or conflict with the stipulations would need to come back through public hearing process to modify and would not be considered minor modification.

- 12 The detention area shall be as shown and reflected on the reference rezoning Plan. The area shall be fenced with a black, vinyl-clad chain link fence a minimum of four (4) feet in height, with landscaping to the exterior for purposes of visual screening. The landscaping shall be approved by Cobb County Arborist during the plan review process. Any exposed concrete walls should be faced with brick or stone. The fencing and landscaping shall be installed as soon as the detention area is constructed.
- 13 Applicant agrees to plant a total of 20 Arbovite trees minimum of 6 feet tall as approved by the county arborist. There will be a six-foot wooden privacy fence along the boundary lines along lots, 1,2, and 3 to provide additional screening from Hedgerow amenities area. The privacy fence is to be maintained by the subject properties HOA with the smooth side facing Hedgerow Homeowners. Applicant agrees to sod the front side and back of each lot.
- 14 Applicant agrees to comply with all Cobb County storm water management requirements applicable to the subject property. Applicant will work closely with the Cobb County engineer to route storm water away from Hedgerow residents and toward the onsite detention area and / or Shallowford Road
- 15 All landscaping references herein shall be approved by Cobb County Arborist as part of the plan review process and incorporated into the overall landscape plan for the proposed community, and shall be irrigated as necessary.
- 16 Applicant agrees to comply with all Cobb County development standards and ordinances relating to project improvements, as except as approved by the Board of Commissioners or by the department of Transportation or Community Development Agency, as the authority may allow
- 17 Applicant agrees to comply with all Cobb County Staff recommendations and comments relating to the proposed development of the subject property.
- 18 There shall be a minimum of one four-inch caliper hardwood tree planted on each lot. Location to be determined by builder.
- 19 Applicant agrees to facilitate a plant rescue by the Ga Native Plant society prior to a Land Disturbance permit being issued.
- 20 Applicant agrees to establishment of a mandatory HOA, which will be responsible for the maintenance and up keep of all common areas, fencing, entrance, signage
- 21 Applicant will record with Cobb County, a list of protective covenants regarding all rules and regulations applicable to this property.
- 22 Applicant is currently working on a landscape plan and I will have completed by the BOC meeting on May 16th.
- 23 If land disturbance permit has not been issued and construction begun within 18 months of the final zoning, the subject property shall revert back to its existing R-20 zoning classification
- 24 Every effort will be made by the builder to complete all construction within 36 months from the start date.
- 25 All exterior lighting will be designed to prevent any stray light from protruding outside the property to prevent light from penetrating onto surrounding properties.

L. P. G.