

APPLICANT: Meritage Homes of Georgia, LLC

PETITION NO: Z-44

PHONE #: 678-348-8361 EMAIL: tyler.vansant@meritagehomes.com

HEARING DATE (PC): 08-01-17

REPRESENTATIVE: J. Kevin Moore

HEARING DATE (BOC): 08-15-17

PHONE #: 770-429-1499 EMAIL: jkm@mijs.com

PRESENT ZONING: R-20

TITLEHOLDER: MULTIPLE TITLEHOLDERS IN ZONING FILE

PROPOSED ZONING: RA-5, RA-6, RM-8

PROPERTY LOCATION: Southwest intersection of Floyd Road and
Glore Road, northern terminus of Green Valley Road

PROPOSED USE: Residential Community

ACCESS TO PROPERTY: Floyd Road, Glore Road

SIZE OF TRACT: 47.515 acres

DISTRICT: 17,19

PHYSICAL CHARACTERISTICS TO SITE: Single-family house,
accessory structure, wooded and undeveloped acreage

LAND LOT(S): 29,30,1073,1074,1147

PARCEL(S): 21,3,24,1

TAXES: PAID X DUE _____

COMMISSION DISTRICT: 4

CONTIGUOUS ZONING/DEVELOPMENT

NORTH: R-20/Briarcliff Estates & single-family houses

SOUTH: R-20 & R-15/Clay Manor Subdivision;
R-20/Single-family house

EAST: R-20/Single-family house; Bradley Acres

WEST: R-20/Single-family house; Glore Estates;
Clay Manor; Briarcliff Estates

Adjacent Future Land Use:

Northeast: Medium Density Residential (MDR),
Neighborhood Activity Center (NAC) and Low
Density Residential (LDR)

Southeast: Medium Density Residential (MDR)

East: Medium Density Residential (MDR)

South: Low Density Residential (LDR)

West: Low Density Residential (LDR)

North: Low Density Residential (LDR)

Northwest: Low Density Residential (LDR)

OPPOSITION: NO. OPPOSED _____ PETITION NO: _____ SPOKESMAN _____

PLANNING COMMISSION RECOMMENDATION

APPROVED _____ MOTION BY _____

REJECTED _____ SECONDED _____

HELD _____ CARRIED _____


BOARD OF COMMISSIONERS DECISION

APPROVED _____ MOTION BY _____


REJECTED _____ SECONDED _____

HELD _____ CARRIED _____


STIPULATIONS:





Z-44 2017-GIS



This map is provided for display and planning purposes only. It is not meant to be a legal description.



-  City Boundary
-  Zoning Boundary

APPLICANT: Meritage Homes of Georgia, LLC

PETITION NO.: Z-44

PRESENT ZONING: R-20

PETITION FOR: RA-5, RA-6, RM-8

ZONING COMMENTS:

Staff Member Responsible: Jason A. Campbell

Land Use Plan Recommendation: LDR +/- 36 acres (1-2.5 units per acre)
& MDR +/- 11 acres (2.5-5 units per acre)

Proposed Number of Units: 174 **Overall Density:** 3.66 **Units/Acre**

Staff estimate for allowable # of units: 83 **Units*** **Increase of:** 91 **Units/Lots**

*Estimate could be higher or lower based on engineered plans taking into account topography, shape of property, utilities, roadways, natural features such as creeks, wetlands, etc., and other unforeseen circumstances.

Applicant is request the RA-5, RA-6 and RM-8 zoning districts for the purpose of developing a 174-unit subdivision, having a mixture of attached and detached single-family homes. The 11.91 acres at the immediate intersection of Floyd Road and Glore Road is proposed to be RM-8 with 19 detached single-family units and 65 townhomes. The RM-8 portion indicates a density of 7.05 units per acre. Continuing southwesterly along Glore Road, and south into the property, 16.23 acres are proposed to be RA-6 with 62 single-family detached units. The RA-6 portion indicates a density of 3.82 units per acre. The 19.335 acres around the existing lake on the southwestern section of the tract, is proposed to RA-5 for 28 single-family detached units. The RA-5 portion indicates a density of 1.45 units per acre. The townhomes will range in size from 1,700 - 2,300 square feet and greater. The single-family houses will be 1,800 – 3,200 square feet and greater. The proposed architecture will consist of brick, stone, stacked stone, shake, board and batten, hardi-plank, or combinations thereof, with accent materials.

The proposed site plan will require the following contemporaneous variances:

1. Waiver of the front setback along Floyd Road from the required 75 feet for an arterial road to 40 feet; and
2. Waiver of the interior rear setback for the RM-8 detached units from the required 30 feet to 10 feet.

Cemetery Preservation: No comment.

APPLICANT: Meritage Homes of Georgia, LLC

PETITION NO.: Z-44

PRESENT ZONING: R-20

PETITION FOR: RA-5, RA-6, RM-8

SCHOOL COMMENTS:

<u>Name of School</u>	<u>Enrollment</u>	<u>Capacity Status</u>	<u>Number of Portable Classrooms</u>
<u>Mableton</u>	<u>1059</u>	<u>904</u>	<u> </u>
Elementary			
<u>Floyd</u>	<u>912</u>	<u>1046</u>	<u> </u>
Middle			
<u>South Cobb</u>	<u>2014</u>	<u>2612</u>	<u> </u>

High

- School attendance zones are subject to revision at any time.

Additional Comments: Approval of this petition will have a significant impact on the enrollment at these schools, and we oppose its approval.

APPLICANT: Meritage Homes of Georgia

PETITION NO.: Z-44

FIRE COMMENTS:

Modifications may be required to incorporate the Cobb County Fire Marshal's Office comments.

GUEST PARKING: When projects contemplate less than 20 foot separation between units, guest parking shall be provided at a ratio of one-half space for each dwelling unit (1 space/ 2 units).

APPLICANT: Meritage Homes of Georgia, LLC

PETITION NO.: Z-44

PRESENT ZONING: R-20

PETITION FOR: RA-5, RA-6 & RM-8

PLANNING COMMENTS:

The applicant is requesting a rezoning from R-20 to RA-5, RA-6 and RM-8 for the purpose of a residential community. The 47.515 acre site is located at the southwest intersection of Floyd Road and Glore Road, and the northern terminus of Green Valley Road.

HB-489 Intergovernmental Agreement Zoning Amendment Notification:

Is the application site within one half (1/2) mile of a city boundary? Yes No
If yes, has the city of _____ been notified? Yes No / N/A

Comprehensive Plan

The parcel is within a Medium Density Residential (MDR) and Low Density Residential (LDR) future land use category, with RSL zoning designation. The purpose of the Medium Density Residential (MDR) category is to provide for areas that are suitable for moderate density housing, between two and one-half (2.5) and five (5) dwelling units per acre. The purpose of the Low Density Residential (LDR) category is to provide for areas that are suitable for low density housing between one (1) and two and one-half (2.5) dwelling units per acre. This category presents a range of densities.

Specific Area Policy Guidelines:

There are no specific policy guidelines for this area in the Comprehensive Plan.

Adjacent Future Land Use:

- Northeast: Medium Density Residential (MDR), Neighborhood Activity Center (NAC) and Low Density Residential (LDR)
- Southeast: Medium Density Residential (MDR)
- East: Medium Density Residential (MDR)
- South: Low Density Residential (LDR)
- West: Low Density Residential (LDR)
- North: Low Density Residential (LDR)
- Northwest: Low Density Residential (LDR)

Master Plan/Corridor Study

The property is not located within the boundary of a Plan or Corridor Study

Historic Preservation

After reviewing various county resources including historic and archeological resource surveys and documented Civil War trench maps, it is determined that a c. 1930 house (4646 Floyd Road) and c. 1940 house (4656 Floyd Road) are located within the project area. Due to the age and location of the structures, information about these resources and their occupants appears to have the potential to contribute significantly to the county's public history. Staff recommends the homes either be incorporated into the development or, alternately, documented if destroyed.

In order to properly document this structures, their inhabitants, and the role they played in Cobb County's history, staff requests a history of the homes and their occupants (as well as archival-quality photographs of the structure, all outbuildings, and its setting) be completed by a cultural resource consultant. These materials should be submitted to the historic preservation planner.

APPLICANT: Meritage Homes of Georgia, LLC

PETITION NO.: Z-44

PRESENT ZONING: R-20

PETITION FOR: RA-5, RA-6 & RM-8

PLANNING COMMENTS:

CONT.

Design Guidelines

Is the parcel in an area with Design Guidelines? Yes No

If yes, design guidelines area _____

Does the current site plan comply with the design requirements?

Incentive Zones

Is the property within an Opportunity Zone? Yes No

The Opportunity Zone is an incentive that provides \$3,500 tax credit per job in eligible areas if two or more jobs are being created. This incentive is available for new or existing businesses.

Is the property within an Enterprise Zone? Yes No

The South Cobb Enterprise Zone is an incentive that provides tax abatements and other economic incentives for qualifying businesses locating or expanding within designated areas for new jobs and capital investments.

Is the property eligible for incentives through the Commercial and Industrial Property Rehabilitation Program? Yes No

The Commercial and Industrial Property Rehabilitation Program is an incentive that provides a reduction in ad valorem property taxes for qualifying redevelopment in eligible areas.

For more information on incentives, please call the Community Development Agency, Planning Division at 770.528.2018 or find information online at <http://economic.cobbcountyga.gov>.

Special Districts

Is this property within the Cumberland Special District #1 (hotel/motel fee)?

Yes No

Is this property within the Cumberland Special District #2 (ad valorem tax)?

Yes No

Is this property within the Six Flags Special Service District?

Yes No

Is the property within the:

Dobbins Airfield Safety Zone?

CZ (Clear Zone)

APZ I (Accident Potential Zone I)

APZ II (Accident Potential Zone II)

Noise Zone

Bird / Wildlife Air Strike Hazard (BASH) area

APPLICANT Meritage Homes of Georgia LLC

PETITION NO. Z-044

PRESENT ZONING R-20

PETITION FOR RA-5,RA-6,RM

WATER COMMENTS: NOTE: Comments reflect only what facilities were in existence at the time of this review.

Available at Development: Yes No

Fire Flow Test Required: Yes No

Size / Location of Existing Water Main(s): 12" DI / W side of Floyd Road

Additional Comments: Also 6" DI in Glore Rd, 6" DI in Green Valley Rd

Developer may be required to install/upgrade water mains, based on fire flow test results or Fire Department Code. This will be resolved in the Plan Review Process.

SEWER COMMENTS: NOTE: Comments reflect only what facilities were in existence at the time of this review.

In Drainage Basin: Yes No

At Development: Yes No

Approximate Distance to Nearest Sewer: SW corner of site at Green Valley Road

Estimated Waste Generation (in G.P.D.): A D F= 27,840 Peak= 69,600

Treatment Plant: South Cobb

Plant Capacity: Available Not Available

Line Capacity: Available Not Available

Projected Plant Availability: 0 - 5 years 5 - 10 years over 10 years

Dry Sewers Required: Yes No

Off-site Easements Required: Yes* No *If off-site easements are required, Developer must submit easements to CCWS for review/approval as to form and stipulations prior to the execution of easements by the property owners. All easement acquisitions are the responsibility of the Developer

Flow Test Required: Yes No

Letter of Allocation issued: Yes No

Septic Tank Recommended by this Department: Yes No

Subject to Health Department Approval: Yes No

Additional Sewer flow study may be required at Plan Review Comments:

Developer will be responsible for connecting to the existing County water and sewer systems, installing and/or upgrading all outfalls and water mains, obtaining on and/or offsite easements, dedication of on and/or offsite water and sewer to Cobb County, as may be required. Rezoning does not guarantee water/sewer availability/capacity unless so stated in writing by the Cobb County Water System. Permit issuances subject to continued treatment plant compliance with EPD discharge requirements.

APPLICANT: Meritage Homes of Georgia, LLC

PETITION NO.: Z-44

PRESENT ZONING: R-20

PETITION FOR: RA-5, RA-6, RM-8

STORMWATER MANAGEMENT COMMENTS

FLOOD HAZARD: YES NO POSSIBLY, NOT VERIFIED

DRAINAGE BASIN: Clay Branch FLOOD HAZARD INFO: Zone A

- FEMA Designated 100 year Floodplain Flood.
- Flood Damage Prevention Ordinance DESIGNATED FLOOD HAZARD.
- Project subject to the Cobb County Flood Damage Prevention Ordinance Requirements.
- Dam Breach zone from (upstream) (**onsite**) lake - need to keep residential buildings out of hazard.

WETLANDS: YES NO POSSIBLY, NOT VERIFIED

Location: identified on site plan.

- The Owner/Developer is responsible for obtaining any required wetland permits from the U.S. Army Corps of Engineer.

STREAMBANK BUFFER ZONE: YES NO POSSIBLY, NOT VERIFIED

- Metropolitan River Protection Area (within 2000' of Chattahoochee River) ARC (review 35' undisturbed buffer each side of waterway).
- Chattahoochee River Corridor Tributary Area - County review (undisturbed buffer each side).
- Georgia Erosion-Sediment Control Law and County Ordinance - **County Review**/State Review.
- Georgia DNR Variance may be required to work in 25 foot streambank buffers.
- County Buffer Ordinance: **50'**, 75', 100' or 200' each side of creek channel.

DOWNSTREAM CONDITIONS

- Potential or Known drainage problems exist for developments downstream from this site.
- Stormwater discharges must be controlled not to exceed the capacity available in the downstream storm drainage system.
- Minimize runoff into public roads.
- Minimize the effect of concentrated stormwater discharges onto adjacent properties.
- Developer must secure any easements required to receive concentrated discharges where none exist naturally
- Existing Lake Downstream .
Additional BMP's for erosion sediment controls will be required.
- Lake Study needed to document sediment levels.
- Stormwater discharges through an established residential neighborhood downstream.
- Project engineer must evaluate the impact of increased volume of runoff generated by the proposed project on receiving streams and existing downstream culvert at Green Valley Road.

APPLICANT: Meritage Homes of Georgia, LLC

PETITION NO.: Z-44

PRESENT ZONING: R-20

PETITION FOR: RA-5, RA-6, RM-8

STORMWATER MANAGEMENT COMMENTS – Continued

SPECIAL SITE CONDITIONS

- Provide comprehensive hydrology/stormwater controls to include development of out parcels.
- Submit all proposed site improvements to Plan Review.
- Any **spring activity** uncovered must be addressed by a qualified geotechnical engineer (PE).
- Structural fill _____ must be placed under the direction of a qualified registered Georgia geotechnical engineer (PE).
- Existing facility.
- Project must comply with the Water Quality requirements of the CWA-NPDES-NPS Permit and County Water Quality Ordinance.
- Water Quality/Quantity contributions of the existing lake/pond on site must be continued as baseline conditions into proposed project.
- Calculate and provide % impervious of project site.
- Revisit design; reduce pavement area to reduce runoff and pollution.

ADDITIONAL COMMENTS

1. This parcel is located at the southwest intersection of Floyd and Glore Roads. It is bordered by Gore Crossing and Glore Estates Subdivisions to the west, Clay Manor Subdivision to the south and a large estate-sized residential parcel to the east. Approximately 30% of the site is open pasture, with the remainder wooded. Average slopes range from 4 to 20%. The entire site drains to the south into and through the Clay Manor Subdivision. There is an existing lake located in the south central portion of the site.
2. The existing downstream subdivisions are older and have limited stormwater conveyance capacity with numerous drainage issues and complaints. As a result, it is recommended that stormwater management be elevated such that each storm discharge is controlled not to exceed the allowable discharge of the next lower, more frequent storm event (ie. 5-year storm event released at 2-year rate; 10-year event at 5-year rate; etc. to 100-year event at 50-year rate).
3. The existing lake as well as two stormwater management facilities are proposed to provide stormwater management for the development. The ponds located in the open space as well as the permanent pool lake must be maintained by the mandatory homeowner’s association. The existing dam must be brought up to current County design standards.
4. Offsite bypass to the southwest into the Glore Estates Subdivision must be limited to pervious areas only due to the age and limited capacity of the existing stormwater conveyance system.

APPLICANT: Meritage Homes of Georgia, LLC

PETITION NO.: Z-44

PRESENT ZONING: R-20

PETITION FOR: RA-5, RA-6, RM-8

TRANSPORTATION COMMENTS:

ROADWAY	ROADWAY CLASSIFICATION	SPEED LIMIT	JURISDICTIONAL CONTROL	MIN. R.O.W. REQUIREMENTS
Floyd Road	Arterial	40 mph	Cobb County	100'
Glore Road	Minor Collector	30 mph	Cobb County	60'
Green Valley Road	Local	25 mph	Cobb County	50'

ROADWAY	LOCATION	AVERAGE DAILY TRIPS	LEVEL OF SERVICE
Floyd Road	North of White Boulevard	29,000	D
Glore Road	West of Floyd Road	1,650	C
Green Valley Road	N/A	N/A	N/A

*Based on 2015AADT counting data taken by GDOT, as published on their website, for Floyd Road.
 Based on 2016 traffic counting data taken by Cobb County DOT for Glore Road.
 Planning Level of Service based on available Average Daily Trips using GRTA guideline thresholds. Classification thresholds for LOS A and LOS B are not available for local roads from this data source.
 LOS C or D is acceptable based on GDOT Design Policy Manual criteria.*

COMMENTS AND OBSERVATIONS

Floyd Road is classified as an arterial and according to the available information the existing right-of-way does not meet the minimum requirements for this classification.

RECOMMENDATIONS

Recommend applicant consider entering into a development agreement pursuant to O.C.G.A. 36-71-13 for dedication of the following system improvements to mitigate traffic concerns: a) donation of right-of-way on the west side of Floyd Road, a minimum of 50' from the roadway centerline.

Recommend applicant consider entering into a development agreement pursuant to O.C.G.A. 36-71-13 for dedication of the following system improvements to mitigate traffic concerns: a) donation of right-of-way on the south side of Glore Road, a minimum of 30' from the roadway centerline.

Recommend applicant be required to meet all Cobb County Development Standards and Ordinances related to project improvements.

Recommend curb, gutter, and sidewalk along the Glore Road frontage.

Recommend curb and gutter along both sides and sidewalk along one side of proposed development roadway.

Recommend private streets be constructed to the Cobb County Standard Specifications.

APPLICANT: Meritage Homes of Georgia, LLC

PETITION NO.: Z-44

PRESENT ZONING: R-20

PETITION FOR: RA-5, RA-6, RM-8

Recommend public roads to end in a circular cul-de-sac per Cobb DOT standards.

Recommend no guest parking in the public right-of-way.

Recommend a left turn lane for the entrance on Glore Road. Recommend location and design be determined during plan review, subject to Cobb County DOT approval.

Recommend Floyd Road access include deceleration lane and left turn lane. Recommend location and design be determined during plan review, subject to Cobb County DOT approval.

Recommend widening the driveway at the proposed signalized access to accommodate one inbound and two outbound lanes.

Recommend adding a fourth approach to the existing signal at Floyd Road at Hicks Road and installing split-phase for north and southbound approaches on Hicks Road. Recommend all signal modifications require the approval of the Signals Department in the Cobb County Department of Transportation. Recommend developer contribute 100% of the cost for traffic signal modifications at the entrance.

Recommend a no access easement for lots along the Floyd Road frontage.

Recommend applicant coordinate with Cobb County DOT prior to development plan approval to ensure compatibility with the proposed SPLOST project D11JO - Floyd Road Trail Phase 2.

Recommend a traffic study. The traffic study should include existing and base year (full build out year) Build and No Build analysis; and horizon year (base year + 10 years) Build and No Build analysis. Study assumptions (such as study intersections, trip distribution and annual growth rate) should be agreed to by Cobb DOT before completing the study.

THIS

PAGE

INTENTIONALLY

LEFT

BLANK

STAFF RECOMMENDATIONS

Z-44 MERITAGE HOMES OF GEORGIA, LLC


- A. It is Staff's opinion that the applicant's rezoning proposal may permit a use that is suitable in view of the use and development of adjacent and nearby properties if developed more consistent with the character of the area. Other properties in the area are zoned for single-family residential, residential senior living and neighborhood retail uses.
- B. It is Staff's opinion that the applicant's rezoning proposal may not have an adverse effect on the usability of adjacent or nearby property as long as the density and intensity are reduced. Abutting properties are zoned for single-family residential use and include properties in the R-20 and R-15 zoning districts.
- C. It is Staff's opinion that the applicant's rezoning proposal may result in a use which would cause an excessive or burdensome use of existing streets, transportation facilities or utilities. The Cobb County School District has concerns that approval of this application will have a significant impact on schools in this area. This opinion can be supported by the departmental comments contained in this analysis.
- D. It is Staff's opinion that the applicant's rezoning proposal is in partial conformity with the policy and intent of the *Cobb County Comprehensive Plan*, which delineates this property to be within the Low Density Residential (LDR) and Medium Density Residential (MDR) land use categories, with LDR have a density range of 1-2.5 units per acre and MDR have a density range of 2.5-5 units per acre. The application indicates a request for RM-8 on the portion of the property that is in the MDR land use category, but the proposed site plan indicates a density of 7.05 units per acre on this portion, exceeding the MDR maximum of 5 units per acre. The remainder of the property is in the LDR land use category and proposes the RA-6 and RA-5 zoning categories. The RA-6 section will have a density of 3.82 units per acre (exceeding the maximum LDR limit of 2.5 units per acre) and the RA-5 section proposes a density of 1.45 units per acre (within the LDR range of 1-2.5 units per acre). Other developments in the area include: Briarcliff Estates (zoned R-20 at approximately 1.355 units per acre); Glore Crossing (zoned R-20 at 1.707 units per acre); Glore Estates, Unit 2 (zoned R-20 at 1.71 units per acre); Clay Manor (zoned R-20 and R-15 at approximately 2.34 units per acre); and Concord Village (zoned RSL at 4.25 units per acre).
- E. It is Staff's opinion that there are existing and changing conditions affecting the use and development of the property which give supporting grounds for deleting the applicant's rezoning proposal to RA-5 and R-12 at a density not exceeding the land use designations on each portion of the property. Staff would recommend the RM-8 part of the property be deleted to RA-5 with a maximum of 5 units per acre. This would fit the character of the area along Floyd Road, which has single-family houses, institutional uses, commercial uses and denser residential uses. Staff would recommend the RA-6 and RA-5 part of the property be deleted to R-12 with a maximum density of 2.5 units per acre. This would be consistent with the character of the area going west on Glore Road into the established R-20 and R-15 subdivisions.

Z-44 MERITAGE HOMES OF GEORGIA, LLC (Continued)

Based on the above analysis, Staff recommends DELETING to RA-5 and R-12 subject to the following conditions:

1. Final site plan to be approved the Board of Commissioners;
2. The RM-8 part of the property be deleted to RA-5 with a maximum of 5 units per acre;
3. The RA-6 and RA-5 part of the property be deleted to R-12 with a maximum density of 2.5 units per acre;
4. Fire Department comments and recommendations;
5. Historic Preservation comments and recommendations;
6. Water and Sewer Division comments and recommendations;
7. Stormwater Management Division comments and recommendations;
8. Department of Transportation comments and recommendations; and
9. Owner/developer to enter into a Development Agreement pursuant to O.C.G.A. §36-71-13 for the dedication of system improvements to mitigate traffic concerns.

The recommendations made by the Planning and Zoning Staff are only the opinions of the Planning and Zoning Staff and are by no means the final decision. The Cobb County Board of Commissioners makes the final decisions on all Rezoning and Land Use Permits at an advertised public hearing.



Application No. Z-44 (2017)
Hearing Dates: PC - 08/01/2017
BOC - 08/15/2017

Summary of Intent for Rezoning*

.....
Part 1. Residential Rezoning Information (attach additional information if needed)

- a) Proposed unit square-footage(s): See Attached
- b) Proposed building architecture: _____
- c) List all requested variances: _____

.....
Part 2. Non-residential Rezoning Information (attach additional information if needed)

- a) Proposed use(s): Not Applicable
- b) Proposed building architecture: Not Applicable
- c) Proposed hours/days of operation: Not Applicable
- d) List all requested variances: Not Applicable

.....
Part 3. Other Pertinent Information (List or attach additional information if needed)

.....
Part 4. Is any of the property included on the proposed site plan owned by the Local, State, or Federal Government?
(Please list all Right-of-Ways, Government owned lots, County owned parcels and/or remnants, etc., and attach a plat clearly showing where these properties are located). None known at this time.

*Applicant specifically reserves the right to amend any information set forth in the Summary of Intent for Rezoning, or any other portion of the Application for Rezoning, at any time during the rezoning process.

ATTACHMENT TO APPLICATION FOR REZONING

Application No.: Z- 44 (2017)
Hearing Dates: August 1, 2017
August 15, 2017



Applicant:
Titleholders:

Meritage Homes of Georgia, LLC
D. Victor Lee; Betty James Barnes;
Carla Barnes Snavelly; and 4730 Floyd Road, LLC

Part 1. Residential Rezoning Information

(a) Proposed unit square footage(s):


- i) Townhomes – 1,700 – 2,300 square feet, and greater;
- ii) Single-family detached homes – 1,800 – 3,200 square feet, and greater.

(b) Proposed building architecture:

Brick, stone, stacked stone, shake, board and batten, hardi-plank, or combinations thereof, with accent materials.

(c) List all requested variances:


None known at this time.



Rear-entry Single Family Detached Homes

RECEIVED
JUN 01 2017
COBB CO. COMM. DEV. AGENCY
ZONING DIVISION







Setting the standard for energy-efficient homes™

Z-44 (2017)
Residential
Renderings

Front-entry Single Family Detached Homes

RECEIVED
JUN 01 2017
COBB CO. COMM. DEV. AGENCY
ZONING DIVISION



RECEIVED
JUN 01 2017
COBB CO. COMM. DEV. AGENCY
ZONING DIVISION



RECEIVED
JUN 01 2017
COBB CO. COMM. DEV. AGENCY
ZONING DIVISION



RECEIVED
JUN 01 2017
COBB CO. COMM. DEV. AGENCY
ZONING DIVISION



R E C E I V E D
JUN 01 2017
COBB CO. COMM. DEV. AGENCY
ZONING DIVISION





Setting the standard for energy-efficient homes™

Z-44 (2017)
Residential
Renderings

Townhomes

RECEIVED
JUN 01 2017
COBB CO. COMM. DEV. AGENCY
ZONING DIVISION



Z-44 (2017)
Residential
Renderings

RECEIVED
JUN 01 2017
COBB CO. COMM. DEV. AGENCY
ZONING DIVISION

